

Cambridge Central School District

ADMINISTRATIVE OFFICES

58 South Park Street Cambridge, NY 12816
518-677-2653 • (fax) 518-677-3889

June 21, 2021

To All Parents / Guardians:

The health and safety of students and staff at the Cambridge Central School District is our number one priority. This letter is to update you on a recent health topic.

As you may be aware, on September 6, 2016, Governor Cuomo signed legislation which requires all public schools in New York State to test all potable water sources for lead every five years. 191 samples were analyzed by Adirondack Environmental Services, Inc., which is certified by the New York State Department of Health (NYSDOH).

Of the 191 samples, 9 sources from areas of drinking and cooking stations tested above the maximum contamination level set by the EPA and NYSDOH of 15 parts per billion. Upon receiving the test results, the district immediately discontinued the use of these water sources for any type of human consumption. The district tagged the sources by posting notices not to consume the water or completely removed the water source as an option. The district will work with the NYSDOH to determine the source of lead and eliminate it.

While we understand that this information may cause you some concern, the district is taking the necessary steps to address the situation and confirm the safety of water throughout the district. There is nothing that we take more seriously than the well-being of our students and staff.

We will keep you informed about this issue and encourage you to contact my office if you have any questions.

Sincerely,



Dr. Douglas Silvernell



Experience is the solution

314 North Pearl Street ♦ Albany, New York 12207
(800) 848-4983 ♦ (518) 434-4546 ♦ Fax (518) 434-0891

June 02, 2021

Rich Austin
Cambridge School District
245 Park Street
Cambridge, NY 12816

Work Order No: 210513024

TEL: (518) 677-8527

RE:

CCS

Dear Rich Austin:

Adirondack Environmental Services, Inc received 191 samples on 5/13/2021 for the analyses presented in the following report.

Please see case narrative for specifics on analysis.

If you have any questions regarding these tests results, please feel free to call.

Sincerely,

A handwritten signature in black ink that reads "Tara Daniels". The signature is written in a cursive style.

Tara Daniels
Laboratory Director

ELAP#: 10709

Cambridge School District

Date: 02-Jun-21

CCS

Lab WorkOrder: 210513024

Sample containers were supplied by Adirondack Environmental Services.

Sample bottles for client IDs "F5", "B14a", and "B14b" were not received.

Sample ID "F1" was not listed on the COC but has been included in this report.

Definitions - RL: Reporting Limit DF: Dilution factor

Qualifiers:	ND : Not Detected at reporting limit	C: CCV below acceptable Limits
	J: Analyte detected below quantitation limit	C+: CCV above acceptable Limits
	B: Analyte detected in Blank	S: LCS Spike recovery is below acceptable limits
	X: Exceeds maximum contamination limit	S+: LCS Spike recovery is above acceptable limits
	H: Hold time exceeded	Z: Duplication outside acceptable limits
	N: Matrix Spike below acceptable limits	T : Tentatively Identified Compound-Estimated
	N+: Matrix Spike is above acceptable limits	E :Above quantitation range-Estimated

Note : All Results are reported as wet weight unless noted

The results relate only to the items tested. Information supplied by the client is assumed to be correct.

Adirondack Environmental Services, Inc

Date: 02-Jun-21

CLIENT: Cambridge School District
Project: CCS

LabWork Order: 210513024
PO#:

Lab SampleID: 210513024-001 **Collection Date:** 5/12/2021
Client Sample ID: 102a **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 5/19/2021)

Lead	ND	1.0		µg/L	1	5/28/2021 1:39:44 AM
------	----	-----	--	------	---	----------------------

Lab SampleID: 210513024-002 **Collection Date:** 5/12/2021
Client Sample ID: 102b **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 5/19/2021)

Lead	ND	1.0		µg/L	1	5/28/2021 1:50:58 AM
------	----	-----	--	------	---	----------------------

Lab SampleID: 210513024-003 **Collection Date:** 5/12/2021
Client Sample ID: 107a **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 5/19/2021)

Lead	ND	1.0		µg/L	1	5/28/2021 1:54:44 AM
------	----	-----	--	------	---	----------------------

Lab SampleID: 210513024-004 **Collection Date:** 5/12/2021
Client Sample ID: 107b **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 5/19/2021)

Lead	ND	1.0		µg/L	1	5/28/2021 2:05:55 AM
------	----	-----	--	------	---	----------------------

Lab SampleID: 210513024-005 **Collection Date:** 5/12/2021
Client Sample ID: 133 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 5/19/2021)

Lead	ND	1.0		µg/L	1	5/28/2021 2:09:40 AM
------	----	-----	--	------	---	----------------------

Adirondack Environmental Services, Inc

Date: 02-Jun-21

CLIENT: Cambridge School District
Project: CCS

LabWork Order: 210513024
PO#:

Lab SampleID: 210513024-007 **Collection Date:** 5/12/2021
Client Sample ID: 131 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
ICP/MS - EPA 200.8 REV 5.4 (Prep: - 5/19/2021) Analyst: SM						
Lead	2.0	1.0		µg/L	1	5/28/2021 2:13:24 AM

Lab SampleID: 210513024-008 **Collection Date:** 5/12/2021
Client Sample ID: B1a **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
ICP/MS - EPA 200.8 REV 5.4 (Prep: - 5/19/2021) Analyst: SM						
Lead	ND	1.0		µg/L	1	5/28/2021 2:17:09 AM

Lab SampleID: 210513024-009 **Collection Date:** 5/12/2021
Client Sample ID: B1b **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
ICP/MS - EPA 200.8 REV 5.4 (Prep: - 5/19/2021) Analyst: SM						
Lead	ND	1.0		µg/L	1	5/28/2021 2:20:53 AM

Lab SampleID: 210513024-010 **Collection Date:** 5/12/2021
Client Sample ID: B3a **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
ICP/MS - EPA 200.8 REV 5.4 (Prep: - 5/19/2021) Analyst: SM						
Lead	ND	1.0		µg/L	1	5/28/2021 2:24:38 AM

Lab SampleID: 210513024-011 **Collection Date:** 5/12/2021
Client Sample ID: B3b **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
ICP/MS - EPA 200.8 REV 5.4 (Prep: - 5/19/2021) Analyst: SM						
Lead	ND	1.0		µg/L	1	5/28/2021 2:28:22 AM

Adirondack Environmental Services, Inc

Date: 02-Jun-21

CLIENT: Cambridge School District
Project: CCS

LabWork Order: 210513024
PO#:

Lab SampleID: 210513024-012
Client Sample ID: B6

Collection Date: 5/12/2021
Matrix: DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 5/19/2021)

Lead	ND	1.0		µg/L	1	5/28/2021 2:32:07 AM
------	----	-----	--	------	---	----------------------

Lab SampleID: 210513024-013
Client Sample ID: 83

Collection Date: 5/12/2021
Matrix: DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 5/19/2021)

Lead	1.9	1.0		µg/L	1	5/28/2021 2:50:49 AM
------	-----	-----	--	------	---	----------------------

Lab SampleID: 210513024-014
Client Sample ID: B7

Collection Date: 5/12/2021
Matrix: DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 5/19/2021)

Lead	39.6	1.0	X	µg/L	1	5/28/2021 2:54:34 AM
------	------	-----	---	------	---	----------------------

Lab SampleID: 210513024-015
Client Sample ID: B8a

Collection Date: 5/12/2021
Matrix: DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 5/19/2021)

Lead	ND	1.0		µg/L	1	5/28/2021 2:58:19 AM
------	----	-----	--	------	---	----------------------

Lab SampleID: 210513024-016
Client Sample ID: B8b

Collection Date: 5/12/2021
Matrix: DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 5/19/2021)

Lead	ND	1.0		µg/L	1	5/28/2021 3:02:04 AM
------	----	-----	--	------	---	----------------------

Adirondack Environmental Services, Inc

Date: 02-Jun-21

CLIENT: Cambridge School District
Project: CCS

LabWork Order: 210513024
PO#:

Lab SampleID: 210513024-017 **Collection Date:** 5/12/2021
Client Sample ID: B10a **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
ICP/MS - EPA 200.8 REV 5.4 Analyst: SM (Prep: - 5/19/2021)						
Lead	ND	1.0		µg/L	1	5/28/2021 3:05:48 AM

Lab SampleID: 210513024-018 **Collection Date:** 5/12/2021
Client Sample ID: B10b **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
ICP/MS - EPA 200.8 REV 5.4 Analyst: SM (Prep: - 5/19/2021)						
Lead	ND	1.0		µg/L	1	5/28/2021 3:09:33 AM

Lab SampleID: 210513024-019 **Collection Date:** 5/12/2021
Client Sample ID: 113a **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
ICP/MS - EPA 200.8 REV 5.4 Analyst: SM (Prep: - 5/19/2021)						
Lead	ND	1.0		µg/L	1	5/28/2021 3:13:18 AM

Lab SampleID: 210513024-020 **Collection Date:** 5/12/2021
Client Sample ID: 113b **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
ICP/MS - EPA 200.8 REV 5.4 Analyst: SM (Prep: - 5/19/2021)						
Lead	ND	1.0		µg/L	1	5/28/2021 3:17:03 AM

Lab SampleID: 210513024-021 **Collection Date:** 5/12/2021
Client Sample ID: 115 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
ICP/MS - EPA 200.8 REV 5.4 Analyst: SM (Prep: - 5/19/2021)						
Lead	ND	1.0		µg/L	1	5/28/2021 3:20:48 AM

Adirondack Environmental Services, Inc

Date: 02-Jun-21

CLIENT: Cambridge School District
Project: CCS

LabWork Order: 210513024
PO#:

Lab SampleID: 210513024-022 **Collection Date:** 5/12/2021
Client Sample ID: 117 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
ICP/MS - EPA 200.8 REV 5.4 Analyst: SM						
(Prep: - 5/19/2021)						
Lead	ND	1.0		µg/L	1	5/28/2021 3:39:30 AM

Lab SampleID: 210513024-023 **Collection Date:** 5/12/2021
Client Sample ID: B12a **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
ICP/MS - EPA 200.8 REV 5.4 Analyst: SM						
(Prep: - 5/19/2021)						
Lead	ND	1.0		µg/L	1	5/28/2021 3:50:45 AM

Lab SampleID: 210513024-024 **Collection Date:** 5/12/2021
Client Sample ID: B12b **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
ICP/MS - EPA 200.8 REV 5.4 Analyst: SM						
(Prep: - 5/19/2021)						
Lead	ND	1.0		µg/L	1	5/28/2021 3:54:31 AM

Lab SampleID: 210513024-027 **Collection Date:** 5/12/2021
Client Sample ID: F2 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
ICP/MS - EPA 200.8 REV 5.4 Analyst: SM						
(Prep: - 5/19/2021)						
Lead	ND	1.0		µg/L	1	5/28/2021 3:58:16 AM

Lab SampleID: 210513024-028 **Collection Date:** 5/12/2021
Client Sample ID: B16a **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
ICP/MS - EPA 200.8 REV 5.4 Analyst: SM						
(Prep: - 5/19/2021)						
Lead	2.0	1.0		µg/L	1	5/28/2021 4:02:01 AM

Adirondack Environmental Services, Inc

Date: 02-Jun-21

CLIENT: Cambridge School District
Project: CCS

LabWork Order: 210513024
PO#:

Lab SampleID: 210513024-029 **Collection Date:** 5/12/2021
Client Sample ID: B16b **Matrix:** DRINKING WATER
Analyses **Result** **RL** **Qual** **Units** **DF** **Date Analyzed**
 ICP/MS - EPA 200.8 REV 5.4 **Analyst:** SM
 (Prep: - 5/19/2021)
 Lead **ND** 1.0 µg/L 1 5/28/2021 4:05:46 AM

Lab SampleID: 210513024-030 **Collection Date:** 5/12/2021
Client Sample ID: B16c **Matrix:** DRINKING WATER
Analyses **Result** **RL** **Qual** **Units** **DF** **Date Analyzed**
 ICP/MS - EPA 200.8 REV 5.4 **Analyst:** SM
 (Prep: - 5/19/2021)
 Lead **ND** 1.0 µg/L 1 5/28/2021 4:09:32 AM

Lab SampleID: 210513024-031 **Collection Date:** 5/12/2021
Client Sample ID: B19a **Matrix:** DRINKING WATER
Analyses **Result** **RL** **Qual** **Units** **DF** **Date Analyzed**
 ICP/MS - EPA 200.8 REV 5.4 **Analyst:** SM
 (Prep: - 5/19/2021)
 Lead **36.1** 1.0 X µg/L 1 5/28/2021 4:20:44 AM

Lab SampleID: 210513024-032 **Collection Date:** 5/12/2021
Client Sample ID: B19b **Matrix:** DRINKING WATER
Analyses **Result** **RL** **Qual** **Units** **DF** **Date Analyzed**
 ICP/MS - EPA 200.8 REV 5.4 **Analyst:** SM
 (Prep: - 5/19/2021)
 Lead **12.7** 1.0 µg/L 1 5/28/2021 4:24:29 AM

Lab SampleID: 210513024-033 **Collection Date:** 5/12/2021
Client Sample ID: B19c **Matrix:** DRINKING WATER
Analyses **Result** **RL** **Qual** **Units** **DF** **Date Analyzed**
 ICP/MS - EPA 200.8 REV 5.4 **Analyst:** SM
 (Prep: - 5/19/2021)
 Lead **5.5** 1.0 µg/L 1 5/28/2021 4:28:15 AM

Adirondack Environmental Services, Inc

Date: 02-Jun-21

CLIENT: Cambridge School District
Project: CCS

LabWork Order: 210513024
PO#:

Lab SampleID: 210513024-034 **Collection Date:** 5/12/2021
Client Sample ID: B22 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
ICP/MS - EPA 200.8 REV 5.4 Analyst: SM						
(Prep: - 5/19/2021)						
Lead	ND	1.0		µg/L	1	5/28/2021 4:32:00 AM

Lab SampleID: 210513024-035 **Collection Date:** 5/12/2021
Client Sample ID: B23 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
ICP/MS - EPA 200.8 REV 5.4 Analyst: SM						
(Prep: - 5/19/2021)						
Lead	ND	1.0		µg/L	1	5/28/2021 4:43:16 AM

Lab SampleID: 210513024-036 **Collection Date:** 5/12/2021
Client Sample ID: F3 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
ICP/MS - EPA 200.8 REV 5.4 Analyst: SM						
(Prep: - 5/19/2021)						
Lead	ND	1.0		µg/L	1	5/28/2021 4:47:02 AM

Lab SampleID: 210513024-037 **Collection Date:** 5/12/2021
Client Sample ID: 214 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
ICP/MS - EPA 200.8 REV 5.4 Analyst: SM						
(Prep: - 5/19/2021)						
Lead	2.4	1.0		µg/L	1	5/28/2021 4:50:48 AM

Lab SampleID: 210513024-038 **Collection Date:** 5/12/2021
Client Sample ID: F-6 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
ICP/MS - EPA 200.8 REV 5.4 Analyst: SM						
(Prep: - 5/19/2021)						
Lead	ND	1.0		µg/L	1	5/28/2021 5:02:01 AM

Adirondack Environmental Services, Inc

Date: 02-Jun-21

CLIENT: Cambridge School District
Project: CCS

LabWork Order: 210513024
PO#:

Lab SampleID: 210513024-039 **Collection Date:** 5/12/2021
Client Sample ID: 15d **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
ICP/MS - EPA 200.8 REV 5.4 Analyst: SM (Prep: - 5/19/2021)						
Lead	1.7	1.0		µg/L	1	5/28/2021 5:05:46 AM

Lab SampleID: 210513024-040 **Collection Date:** 5/12/2021
Client Sample ID: B24 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
ICP/MS - EPA 200.8 REV 5.4 Analyst: SM (Prep: - 5/19/2021)						
Lead	ND	1.0		µg/L	1	5/28/2021 5:09:32 AM

Lab SampleID: 210513024-041 **Collection Date:** 5/12/2021
Client Sample ID: B25 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
ICP/MS - EPA 200.8 REV 5.4 Analyst: SM (Prep: - 5/19/2021)						
Lead	ND	1.0		µg/L	1	5/28/2021 5:13:17 AM

Lab SampleID: 210513024-042 **Collection Date:** 5/12/2021
Client Sample ID: 12 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
ICP/MS - EPA 200.8 REV 5.4 Analyst: SM (Prep: - 5/19/2021)						
Lead	ND	1.0		µg/L	1	5/28/2021 5:17:03 AM

Lab SampleID: 210513024-043 **Collection Date:** 5/12/2021
Client Sample ID: 15a **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
ICP/MS - EPA 200.8 REV 5.4 Analyst: SM (Prep: - 5/19/2021)						
Lead	ND	1.0		µg/L	1	5/28/2021 5:20:48 AM

Adirondack Environmental Services, Inc

Date: 02-Jun-21

CLIENT: Cambridge School District
Project: CCS

LabWork Order: 210513024
PO#:

Lab SampleID: 210513024-044 **Collection Date:** 5/12/2021
Client Sample ID: 15b **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
ICP/MS - EPA 200.8 REV 5.4 Analyst: SM						
(Prep: - 5/19/2021)						
Lead	ND	1.0		µg/L	1	5/28/2021 5:32:05 AM

Lab SampleID: 210513024-045 **Collection Date:** 5/12/2021
Client Sample ID: 15c **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
ICP/MS - EPA 200.8 REV 5.4 Analyst: SM						
(Prep: - 5/19/2021)						
Lead	45.3	1.0	X	µg/L	1	5/28/2021 5:50:50 AM

Lab SampleID: 210513024-046 **Collection Date:** 5/12/2021
Client Sample ID: 15c **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
ICP/MS - EPA 200.8 REV 5.4 Analyst: SM						
(Prep: - 5/19/2021)						
Lead	ND	1.0		µg/L	1	5/28/2021 5:54:36 AM

Lab SampleID: 210513024-047 **Collection Date:** 5/12/2021
Client Sample ID: 15f **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
ICP/MS - EPA 200.8 REV 5.4 Analyst: SM						
(Prep: - 5/19/2021)						
Lead	ND	1.0		µg/L	1	5/28/2021 5:58:22 AM

Lab SampleID: 210513024-048 **Collection Date:** 5/12/2021
Client Sample ID: B26a **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
ICP/MS - EPA 200.8 REV 5.4 Analyst: SM						
(Prep: - 5/19/2021)						
Lead	ND	1.0		µg/L	1	5/28/2021 6:02:08 AM

Adirondack Environmental Services, Inc

Date: 02-Jun-21

CLIENT: Cambridge School District
Project: CCS

LabWork Order: 210513024
PO#:

Lab SampleID: 210513024-049

Collection Date: 5/12/2021

Client Sample ID: B26b

Matrix: DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
ICP/MS - EPA 200.8 REV 5.4 (Prep: - 5/19/2021) Analyst: SM						
Lead	22.9	1.0	X	µg/L	1	5/28/2021 6:05:53 AM

Lab SampleID: 210513024-050

Collection Date: 5/12/2021

Client Sample ID: B26c

Matrix: DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
ICP/MS - EPA 200.8 REV 5.4 (Prep: - 5/19/2021) Analyst: SM						
Lead	49.0	1.0	X	µg/L	1	5/28/2021 6:09:39 AM

Lab SampleID: 210513024-051

Collection Date: 5/12/2021

Client Sample ID: B26d

Matrix: DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
ICP/MS - EPA 200.8 REV 5.4 (Prep: - 5/19/2021) Analyst: SM						
Lead	ND	1.0		µg/L	1	6/1/2021

Lab SampleID: 210513024-052

Collection Date: 5/12/2021

Client Sample ID: B27a

Matrix: DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
ICP/MS - EPA 200.8 REV 5.4 (Prep: - 5/19/2021) Analyst: SM						
Lead	ND	1.0		µg/L	1	6/1/2021

Lab SampleID: 210513024-053

Collection Date: 5/12/2021

Client Sample ID: B27b

Matrix: DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
ICP/MS - EPA 200.8 REV 5.4 (Prep: - 5/19/2021) Analyst: SM						
Lead	4.9	1.0		µg/L	1	6/1/2021

Adirondack Environmental Services, Inc

Date: 02-Jun-21

CLIENT: Cambridge School District
Project: CCS

LabWork Order: 210513024
PO#:

Lab SampleID: 210513024-054
Client Sample ID: B27c

Collection Date: 5/12/2021
Matrix: DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 5/19/2021)

Lead	8.2	1.0		µg/L	1	6/1/2021
------	-----	-----	--	------	---	----------

Lab SampleID: 210513024-055
Client Sample ID: B27d

Collection Date: 5/12/2021
Matrix: DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 5/19/2021)

Lead	ND	1.0		µg/L	1	6/1/2021
------	----	-----	--	------	---	----------

Lab SampleID: 210513024-056
Client Sample ID: 56

Collection Date: 5/12/2021
Matrix: DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 5/19/2021)

Lead	ND	1.0		µg/L	1	6/1/2021
------	----	-----	--	------	---	----------

Lab SampleID: 210513024-057
Client Sample ID: F-8

Collection Date: 5/12/2021
Matrix: DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 5/19/2021)

Lead	ND	1.0		µg/L	1	6/1/2021
------	----	-----	--	------	---	----------

Lab SampleID: 210513024-058
Client Sample ID: 54

Collection Date: 5/12/2021
Matrix: DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 5/19/2021)

Lead	ND	1.0		µg/L	1	6/1/2021
------	----	-----	--	------	---	----------

Adirondack Environmental Services, Inc

Date: 02-Jun-21

CLIENT: Cambridge School District
Project: CCS

LabWork Order: 210513024
PO#:

Lab SampleID: 210513024-059
Client Sample ID: 52

Collection Date: 5/12/2021
Matrix: DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 5/19/2021)

Lead	ND	1.0		µg/L	1	6/1/2021
------	----	-----	--	------	---	----------

Lab SampleID: 210513024-060
Client Sample ID: 51

Collection Date: 5/12/2021
Matrix: DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 5/19/2021)

Lead	ND	1.0		µg/L	1	6/1/2021
------	----	-----	--	------	---	----------

Lab SampleID: 210513024-061
Client Sample ID: 50

Collection Date: 5/12/2021
Matrix: DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 5/19/2021)

Lead	ND	1.0		µg/L	1	6/1/2021
------	----	-----	--	------	---	----------

Lab SampleID: 210513024-062
Client Sample ID: F9

Collection Date: 5/12/2021
Matrix: DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 5/19/2021)

Lead	ND	1.0		µg/L	1	6/1/2021
------	----	-----	--	------	---	----------

Lab SampleID: 210513024-063
Client Sample ID: 47a

Collection Date: 5/12/2021
Matrix: DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 5/19/2021)

Lead	ND	1.0		µg/L	1	6/1/2021
------	----	-----	--	------	---	----------

Adirondack Environmental Services, Inc

Date: 02-Jun-21

CLIENT: Cambridge School District
Project: CCS

LabWork Order: 210513024
PO#:

Lab SampleID: 210513024-064 **Collection Date:** 5/12/2021
Client Sample ID: 47b **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 5/19/2021)

Lead	ND	1.0		µg/L	1	6/1/2021
------	----	-----	--	------	---	----------

Lab SampleID: 210513024-065 **Collection Date:** 5/12/2021
Client Sample ID: 48a **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 5/19/2021)

Lead	ND	1.0		µg/L	1	6/1/2021
------	----	-----	--	------	---	----------

Lab SampleID: 210513024-066 **Collection Date:** 5/12/2021
Client Sample ID: 48b **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 5/19/2021)

Lead	ND	1.0		µg/L	1	6/1/2021
------	----	-----	--	------	---	----------

Lab SampleID: 210513024-067 **Collection Date:** 5/12/2021
Client Sample ID: 46a **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 5/19/2021)

Lead	ND	1.0		µg/L	1	6/1/2021
------	----	-----	--	------	---	----------

Lab SampleID: 210513024-068 **Collection Date:** 5/12/2021
Client Sample ID: 46b **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 5/19/2021)

Lead	ND	1.0		µg/L	1	6/1/2021
------	----	-----	--	------	---	----------

Adirondack Environmental Services, Inc

Date: 02-Jun-21

CLIENT: Cambridge School District
Project: CCS

LabWork Order: 210513024
PO#:

Lab SampleID: 210513024-069 **Collection Date:** 5/12/2021
Client Sample ID: B28 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 5/19/2021)

Lead	ND	1.0		µg/L	1	6/1/2021
------	----	-----	--	------	---	----------

Lab SampleID: 210513024-070 **Collection Date:** 5/12/2021
Client Sample ID: B29 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 5/19/2021)

Lead	ND	1.0		µg/L	1	6/1/2021
------	----	-----	--	------	---	----------

Lab SampleID: 210513024-071 **Collection Date:** 5/12/2021
Client Sample ID: 44a **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 5/19/2021)

Lead	ND	1.0		µg/L	1	6/1/2021
------	----	-----	--	------	---	----------

Lab SampleID: 210513024-072 **Collection Date:** 5/12/2021
Client Sample ID: 44b **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 5/19/2021)

Lead	ND	1.0		µg/L	1	6/1/2021
------	----	-----	--	------	---	----------

Lab SampleID: 210513024-073 **Collection Date:** 5/12/2021
Client Sample ID: 42a **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 5/19/2021)

Lead	ND	1.0		µg/L	1	6/1/2021
------	----	-----	--	------	---	----------

Adirondack Environmental Services, Inc

Date: 02-Jun-21

CLIENT: Cambridge School District
Project: CCS

LabWork Order: 210513024
PO#:

Lab SampleID: 210513024-074 **Collection Date:** 5/12/2021
Client Sample ID: 40a **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 5/19/2021)

Lead	ND	1.0	N	µg/L	1	6/1/2021
------	----	-----	---	------	---	----------

Lab SampleID: 210513024-075 **Collection Date:** 5/12/2021
Client Sample ID: 40b **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 5/19/2021)

Lead	ND	1.0		µg/L	1	6/1/2021
------	----	-----	--	------	---	----------

Lab SampleID: 210513024-076 **Collection Date:** 5/12/2021
Client Sample ID: 39a **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 5/19/2021)

Lead	ND	1.0		µg/L	1	6/1/2021
------	----	-----	--	------	---	----------

Lab SampleID: 210513024-077 **Collection Date:** 5/12/2021
Client Sample ID: 39b **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 5/19/2021)

Lead	ND	1.0		µg/L	1	6/1/2021
------	----	-----	--	------	---	----------

Lab SampleID: 210513024-078 **Collection Date:** 5/12/2021
Client Sample ID: 38a **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 5/19/2021)

Lead	ND	1.0		µg/L	1	6/1/2021
------	----	-----	--	------	---	----------

Adirondack Environmental Services, Inc

Date: 02-Jun-21

CLIENT: Cambridge School District
Project: CCS

LabWork Order: 210513024
PO#:

Lab SampleID: 210513024-079
Client Sample ID: 38b

Collection Date: 5/12/2021
Matrix: DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 5/19/2021)

Lead	ND	1.0		µg/L	1	6/1/2021
------	----	-----	--	------	---	----------

Lab SampleID: 210513024-080
Client Sample ID: 37a

Collection Date: 5/12/2021
Matrix: DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 5/19/2021)

Lead	ND	1.0		µg/L	1	6/1/2021
------	----	-----	--	------	---	----------

Lab SampleID: 210513024-081
Client Sample ID: 37b

Collection Date: 5/12/2021
Matrix: DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 5/19/2021)

Lead	ND	1.0		µg/L	1	6/1/2021
------	----	-----	--	------	---	----------

Lab SampleID: 210513024-082
Client Sample ID: 36a

Collection Date: 5/12/2021
Matrix: DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 5/19/2021)

Lead	ND	1.0		µg/L	1	6/1/2021
------	----	-----	--	------	---	----------

Lab SampleID: 210513024-083
Client Sample ID: 36b

Collection Date: 5/12/2021
Matrix: DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 5/19/2021)

Lead	ND	1.0		µg/L	1	6/1/2021
------	----	-----	--	------	---	----------

Adirondack Environmental Services, Inc

Date: 02-Jun-21

CLIENT: Cambridge School District
Project: CCS

LabWork Order: 210513024
PO#:

Lab SampleID: 210513024-084
Client Sample ID: 35a

Collection Date: 5/12/2021
Matrix: DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4						Analyst: SM
(Prep: - 5/19/2021)						
Lead	ND	1.0		µg/L	1	6/1/2021

Lab SampleID: 210513024-085
Client Sample ID: 35b

Collection Date: 5/12/2021
Matrix: DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4						Analyst: SM
(Prep: - 5/19/2021)						
Lead	ND	1.0		µg/L	1	6/1/2021

Lab SampleID: 210513024-086
Client Sample ID: 34a

Collection Date: 5/12/2021
Matrix: DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4						Analyst: SM
(Prep: - 5/19/2021)						
Lead	ND	1.0		µg/L	1	6/1/2021

Lab SampleID: 210513024-087
Client Sample ID: 34b

Collection Date: 5/12/2021
Matrix: DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4						Analyst: SM
(Prep: - 5/19/2021)						
Lead	ND	1.0		µg/L	1	6/1/2021

Lab SampleID: 210513024-088
Client Sample ID: 32a

Collection Date: 5/12/2021
Matrix: DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4						Analyst: SM
(Prep: - 5/19/2021)						
Lead	ND	1.0		µg/L	1	6/1/2021

Adirondack Environmental Services, Inc

Date: 02-Jun-21

CLIENT: Cambridge School District
Project: CCS

LabWork Order: 210513024
PO#:

Lab SampleID: 210513024-089
Client Sample ID: 32b

Collection Date: 5/12/2021
Matrix: DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 5/19/2021)

Lead	ND	1.0		µg/L	1	6/1/2021
------	----	-----	--	------	---	----------

Lab SampleID: 210513024-090
Client Sample ID: 32c

Collection Date: 5/12/2021
Matrix: DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 5/19/2021)

Lead	1.5	1.0		µg/L	1	6/1/2021
------	-----	-----	--	------	---	----------

Lab SampleID: 210513024-091
Client Sample ID: F10

Collection Date: 5/12/2021
Matrix: DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 5/19/2021)

Lead	ND	1.0		µg/L	1	6/1/2021
------	----	-----	--	------	---	----------

Lab SampleID: 210513024-092
Client Sample ID: 31a

Collection Date: 5/12/2021
Matrix: DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 5/19/2021)

Lead	ND	1.0		µg/L	1	6/1/2021
------	----	-----	--	------	---	----------

Lab SampleID: 210513024-093
Client Sample ID: 31b

Collection Date: 5/12/2021
Matrix: DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 5/19/2021)

Lead	ND	1.0		µg/L	1	6/1/2021
------	----	-----	--	------	---	----------

Adirondack Environmental Services, Inc

Date: 02-Jun-21

CLIENT: Cambridge School District
Project: CCS

LabWork Order: 210513024
PO#:

Lab SampleID: 210513024-094 **Collection Date:** 5/12/2021
Client Sample ID: 30a **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
ICP/MS - EPA 200.8 REV 5.4 Analyst: SM						
(Prep: - 5/19/2021)						
Lead	1.5	1.0		µg/L	1	6/1/2021

Lab SampleID: 210513024-095 **Collection Date:** 5/12/2021
Client Sample ID: 30b **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
ICP/MS - EPA 200.8 REV 5.4 Analyst: SM						
(Prep: - 5/19/2021)						
Lead	5.7	1.0		µg/L	1	6/1/2021

Lab SampleID: 210513024-096 **Collection Date:** 5/12/2021
Client Sample ID: 29a **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
ICP/MS - EPA 200.8 REV 5.4 Analyst: SM						
(Prep: - 5/19/2021)						
Lead	ND	1.0		µg/L	1	6/1/2021

Lab SampleID: 210513024-097 **Collection Date:** 5/12/2021
Client Sample ID: 28a **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
ICP/MS - EPA 200.8 REV 5.4 Analyst: SM						
(Prep: - 5/19/2021)						
Lead	ND	1.0		µg/L	1	6/1/2021

Lab SampleID: 210513024-098 **Collection Date:** 5/12/2021
Client Sample ID: 28b **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
ICP/MS - EPA 200.8 REV 5.4 Analyst: SM						
(Prep: - 5/19/2021)						
Lead	ND	1.0		µg/L	1	6/1/2021

Adirondack Environmental Services, Inc

Date: 02-Jun-21

CLIENT: Cambridge School District
Project: CCS

LabWork Order: 210513024
PO#:

Lab SampleID: 210513024-099
Client Sample ID: 27a

Collection Date: 5/12/2021
Matrix: DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 5/19/2021)

Lead	ND	1.0		µg/L	1	6/1/2021
------	----	-----	--	------	---	----------

Lab SampleID: 210513024-100
Client Sample ID: 27b

Collection Date: 5/12/2021
Matrix: DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 5/19/2021)

Lead	1.1	1.0		µg/L	1	6/1/2021
------	-----	-----	--	------	---	----------

Lab SampleID: 210513024-101
Client Sample ID: 26a

Collection Date: 5/12/2021
Matrix: DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 5/19/2021)

Lead	ND	1.0		µg/L	1	6/1/2021
------	----	-----	--	------	---	----------

Lab SampleID: 210513024-102
Client Sample ID: 26b

Collection Date: 5/12/2021
Matrix: DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 5/19/2021)

Lead	1.1	1.0		µg/L	1	6/1/2021
------	-----	-----	--	------	---	----------

Lab SampleID: 210513024-103
Client Sample ID: 25a

Collection Date: 5/12/2021
Matrix: DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 5/19/2021)

Lead	ND	1.0		µg/L	1	6/1/2021
------	----	-----	--	------	---	----------

Adirondack Environmental Services, Inc

Date: 02-Jun-21

CLIENT: Cambridge School District
Project: CCS

LabWork Order: 210513024
PO#:

Lab SampleID: 210513024-104 **Collection Date:** 5/12/2021
Client Sample ID: 25b **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 5/19/2021)

Lead	ND	1.0		µg/L	1	6/1/2021
------	----	-----	--	------	---	----------

Lab SampleID: 210513024-105 **Collection Date:** 5/12/2021
Client Sample ID: 24a **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 5/19/2021)

Lead	15.5	1.0	X	µg/L	1	6/1/2021
------	------	-----	---	------	---	----------

Lab SampleID: 210513024-106 **Collection Date:** 5/12/2021
Client Sample ID: 24b **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 5/19/2021)

Lead	3.1	1.0		µg/L	1	6/1/2021
------	-----	-----	--	------	---	----------

Lab SampleID: 210513024-107 **Collection Date:** 5/12/2021
Client Sample ID: 23a **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 5/19/2021)

Lead	1.3	1.0		µg/L	1	6/1/2021
------	-----	-----	--	------	---	----------

Lab SampleID: 210513024-108 **Collection Date:** 5/12/2021
Client Sample ID: 23b **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 5/19/2021)

Lead	3.4	1.0		µg/L	1	6/1/2021
------	-----	-----	--	------	---	----------

Adirondack Environmental Services, Inc

Date: 02-Jun-21

CLIENT: Cambridge School District
Project: CCS

LabWork Order: 210513024
PO#:

Lab SampleID: 210513024-109 **Collection Date:** 5/12/2021
Client Sample ID: 58 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 5/19/2021)

Lead	ND	1.0		µg/L	1	6/1/2021
------	----	-----	--	------	---	----------

Lab SampleID: 210513024-110 **Collection Date:** 5/12/2021
Client Sample ID: 60 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 5/19/2021)

Lead	ND	1.0		µg/L	1	6/1/2021
------	----	-----	--	------	---	----------

Lab SampleID: 210513024-111 **Collection Date:** 5/12/2021
Client Sample ID: 62 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 5/19/2021)

Lead	ND	1.0		µg/L	1	6/1/2021
------	----	-----	--	------	---	----------

Lab SampleID: 210513024-112 **Collection Date:** 5/12/2021
Client Sample ID: 64 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 5/19/2021)

Lead	ND	1.0		µg/L	1	6/1/2021
------	----	-----	--	------	---	----------

Lab SampleID: 210513024-113 **Collection Date:** 5/12/2021
Client Sample ID: 66a **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 5/19/2021)

Lead	ND	1.0		µg/L	1	6/1/2021
------	----	-----	--	------	---	----------

Adirondack Environmental Services, Inc

Date: 02-Jun-21

CLIENT: Cambridge School District
Project: CCS

LabWork Order: 210513024
PO#:

Lab SampleID: 210513024-114 **Collection Date:** 5/12/2021
Client Sample ID: F13 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
ICP/MS - EPA 200.8 REV 5.4 Analyst: SM (Prep: - 5/19/2021)						
Lead	ND	1.0		µg/L	1	6/1/2021

Lab SampleID: 210513024-115 **Collection Date:** 5/12/2021
Client Sample ID: 65a **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
ICP/MS - EPA 200.8 REV 5.4 Analyst: SM (Prep: - 5/19/2021)						
Lead	ND	1.0		µg/L	1	6/1/2021

Lab SampleID: 210513024-116 **Collection Date:** 5/12/2021
Client Sample ID: 65b **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
ICP/MS - EPA 200.8 REV 5.4 Analyst: SM (Prep: - 5/19/2021)						
Lead	ND	1.0		µg/L	1	6/1/2021

Lab SampleID: 210513024-117 **Collection Date:** 5/12/2021
Client Sample ID: 67a **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
ICP/MS - EPA 200.8 REV 5.4 Analyst: SM (Prep: - 5/19/2021)						
Lead	ND	1.0		µg/L	1	6/1/2021

Lab SampleID: 210513024-118 **Collection Date:** 5/12/2021
Client Sample ID: 67b **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
ICP/MS - EPA 200.8 REV 5.4 Analyst: SM (Prep: - 5/19/2021)						
Lead	ND	1.0		µg/L	1	6/1/2021

Adirondack Environmental Services, Inc

Date: 02-Jun-21

CLIENT: Cambridge School District
Project: CCS

LabWork Order: 210513024
PO#:

Lab SampleID: 210513024-119 **Collection Date:** 5/12/2021
Client Sample ID: 68a **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
ICP/MS - EPA 200.8 REV 5.4 Analyst: SM (Prep: - 5/19/2021)						
Lead	ND	1.0		µg/L	1	6/1/2021

Lab SampleID: 210513024-120 **Collection Date:** 5/12/2021
Client Sample ID: 68b **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
ICP/MS - EPA 200.8 REV 5.4 Analyst: SM (Prep: - 5/19/2021)						
Lead	1.2	1.0		µg/L	1	6/1/2021

Lab SampleID: 210513024-121 **Collection Date:** 5/12/2021
Client Sample ID: 70a **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
ICP/MS - EPA 200.8 REV 5.4 Analyst: SM (Prep: - 5/19/2021)						
Lead	ND	1.0		µg/L	1	6/1/2021

Lab SampleID: 210513024-122 **Collection Date:** 5/12/2021
Client Sample ID: 70b **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
ICP/MS - EPA 200.8 REV 5.4 Analyst: SM (Prep: - 5/19/2021)						
Lead	2.1	1.0		µg/L	1	6/1/2021

Lab SampleID: 210513024-123 **Collection Date:** 5/12/2021
Client Sample ID: 72 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
ICP/MS - EPA 200.8 REV 5.4 Analyst: SM (Prep: - 5/19/2021)						
Lead	5.8	1.0		µg/L	1	6/1/2021

Adirondack Environmental Services, Inc

Date: 02-Jun-21

CLIENT: Cambridge School District
Project: CCS

LabWork Order: 210513024
PO#:

Lab SampleID: 210513024-124 **Collection Date:** 5/12/2021
Client Sample ID: B30a **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 5/19/2021)

Lead	ND	1.0		µg/L	1	6/1/2021
------	----	-----	--	------	---	----------

Lab SampleID: 210513024-125 **Collection Date:** 5/12/2021
Client Sample ID: B30b **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 5/19/2021)

Lead	1.4	1.0		µg/L	1	6/1/2021
------	-----	-----	--	------	---	----------

Lab SampleID: 210513024-126 **Collection Date:** 5/12/2021
Client Sample ID: B30c **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 5/19/2021)

Lead	ND	1.0		µg/L	1	6/1/2021
------	----	-----	--	------	---	----------

Lab SampleID: 210513024-127 **Collection Date:** 5/12/2021
Client Sample ID: B31a **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 5/19/2021)

Lead	ND	1.0		µg/L	1	6/1/2021
------	----	-----	--	------	---	----------

Lab SampleID: 210513024-128 **Collection Date:** 5/12/2021
Client Sample ID: B31b **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 5/19/2021)

Lead	ND	1.0		µg/L	1	6/1/2021
------	----	-----	--	------	---	----------

Adirondack Environmental Services, Inc

Date: 02-Jun-21

CLIENT: Cambridge School District
Project: CCS

LabWork Order: 210513024
PO#:

Lab SampleID: 210513024-129 **Collection Date:** 5/12/2021
Client Sample ID: B31c **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 5/19/2021)

Lead	ND	1.0		µg/L	1	6/1/2021
------	----	-----	--	------	---	----------

Lab SampleID: 210513024-130 **Collection Date:** 5/12/2021
Client Sample ID: 80 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 5/19/2021)

Lead	3.1	1.0		µg/L	1	6/1/2021
------	-----	-----	--	------	---	----------

Lab SampleID: 210513024-131 **Collection Date:** 5/12/2021
Client Sample ID: 82 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 5/19/2021)

Lead	3.9	1.0		µg/L	1	6/1/2021
------	-----	-----	--	------	---	----------

Lab SampleID: 210513024-132 **Collection Date:** 5/12/2021
Client Sample ID: 84a **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 5/19/2021)

Lead	ND	1.0		µg/L	1	6/1/2021
------	----	-----	--	------	---	----------

Lab SampleID: 210513024-133 **Collection Date:** 5/12/2021
Client Sample ID: 84b **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 5/19/2021)

Lead	ND	1.0		µg/L	1	6/1/2021
------	----	-----	--	------	---	----------

Adirondack Environmental Services, Inc

Date: 02-Jun-21

CLIENT: Cambridge School District
Project: CCS

LabWork Order: 210513024
PO#:

Lab SampleID: 210513024-134 **Collection Date:** 5/12/2021
Client Sample ID: 84c **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 5/19/2021)

Lead	ND	1.0		µg/L	1	6/1/2021
------	----	-----	--	------	---	----------

Lab SampleID: 210513024-135 **Collection Date:** 5/12/2021
Client Sample ID: 84d **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 5/19/2021)

Lead	ND	1.0		µg/L	1	6/1/2021
------	----	-----	--	------	---	----------

Lab SampleID: 210513024-136 **Collection Date:** 5/12/2021
Client Sample ID: 84c **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 5/19/2021)

Lead	1.4	1.0		µg/L	1	6/1/2021
------	-----	-----	--	------	---	----------

Lab SampleID: 210513024-137 **Collection Date:** 5/12/2021
Client Sample ID: 84f **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 5/19/2021)

Lead	9.7	1.0		µg/L	1	6/1/2021
------	-----	-----	--	------	---	----------

Lab SampleID: 210513024-138 **Collection Date:** 5/12/2021
Client Sample ID: Kitchen a **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 5/19/2021)

Lead	ND	1.0		µg/L	1	6/1/2021
------	----	-----	--	------	---	----------

Adirondack Environmental Services, Inc

Date: 02-Jun-21

CLIENT: Cambridge School District
Project: CCS

LabWork Order: 210513024
PO#:

Lab SampleID: 210513024-139 **Collection Date:** 5/12/2021
Client Sample ID: Kitchen b **Matrix:** DRINKING WATER
Analyses **Result** **RL Qual Units** **DF** **Date Analyzed**

ICP/MS - EPA 200.8 REV 5.4 **Analyst: SM**
(Prep: - 5/19/2021)

Lead	ND	1.0	µg/L	1	6/1/2021
------	----	-----	------	---	----------

Lab SampleID: 210513024-140 **Collection Date:** 5/12/2021
Client Sample ID: Kitchen c **Matrix:** DRINKING WATER
Analyses **Result** **RL Qual Units** **DF** **Date Analyzed**

ICP/MS - EPA 200.8 REV 5.4 **Analyst: SM**
(Prep: - 5/19/2021)

Lead	3.0	1.0	µg/L	1	6/1/2021
------	-----	-----	------	---	----------

Lab SampleID: 210513024-141 **Collection Date:** 5/12/2021
Client Sample ID: Kitchen d **Matrix:** DRINKING WATER
Analyses **Result** **RL Qual Units** **DF** **Date Analyzed**

ICP/MS - EPA 200.8 REV 5.4 **Analyst: SM**
(Prep: - 5/19/2021)

Lead	ND	1.0	µg/L	1	6/1/2021
------	----	-----	------	---	----------

Lab SampleID: 210513024-142 **Collection Date:** 5/12/2021
Client Sample ID: Kitchen e **Matrix:** DRINKING WATER
Analyses **Result** **RL Qual Units** **DF** **Date Analyzed**

ICP/MS - EPA 200.8 REV 5.4 **Analyst: SM**
(Prep: - 5/19/2021)

Lead	1.1	1.0	µg/L	1	6/1/2021
------	-----	-----	------	---	----------

Lab SampleID: 210513024-143 **Collection Date:** 5/12/2021
Client Sample ID: Kitchen f **Matrix:** DRINKING WATER
Analyses **Result** **RL Qual Units** **DF** **Date Analyzed**

ICP/MS - EPA 200.8 REV 5.4 **Analyst: SM**
(Prep: - 5/19/2021)

Lead	16.2	1.0	X µg/L	1	6/1/2021 3:56:29 PM
------	------	-----	--------	---	---------------------

Adirondack Environmental Services, Inc

Date: 02-Jun-21

CLIENT: Cambridge School District
Project: CCS

LabWork Order: 210513024
PO#:

Lab SampleID: 210513024-144 **Collection Date:** 5/12/2021
Client Sample ID: Kitchen g **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
ICP/MS - EPA 200.8 REV 5.4 Analyst: SM						
(Prep: - 5/19/2021)						
Lead	ND	1.0		µg/L	1	6/1/2021 4:00:13 PM

Lab SampleID: 210513024-145 **Collection Date:** 5/12/2021
Client Sample ID: Kitchen H **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
ICP/MS - EPA 200.8 REV 5.4 Analyst: SM						
(Prep: - 5/19/2021)						
Lead	ND	1.0		µg/L	1	6/1/2021 4:11:25 PM

Lab SampleID: 210513024-146 **Collection Date:** 5/12/2021
Client Sample ID: Kitchen I **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
ICP/MS - EPA 200.8 REV 5.4 Analyst: SM						
(Prep: - 5/19/2021)						
Lead	ND	1.0		µg/L	1	6/1/2021 4:15:10 PM

Lab SampleID: 210513024-147 **Collection Date:** 5/12/2021
Client Sample ID: Kitchen J **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
ICP/MS - EPA 200.8 REV 5.4 Analyst: SM						
(Prep: - 5/19/2021)						
Lead	1.4	1.0		µg/L	1	6/1/2021 4:18:55 PM

Lab SampleID: 210513024-148 **Collection Date:** 5/12/2021
Client Sample ID: Kitchen K **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
ICP/MS - EPA 200.8 REV 5.4 Analyst: SM						
(Prep: - 5/19/2021)						
Lead	ND	1.0		µg/L	1	6/1/2021 4:22:40 PM

Adirondack Environmental Services, Inc

Date: 02-Jun-21

CLIENT: Cambridge School District
Project: CCS

LabWork Order: 210513024
PO#:

Lab SampleID: 210513024-149 **Collection Date:** 5/12/2021
Client Sample ID: Kitchen L **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 5/19/2021)

Lead	ND	1.0		µg/L	1	6/1/2021 4:49:24 PM
------	----	-----	--	------	---	---------------------

Lab SampleID: 210513024-150 **Collection Date:** 5/12/2021
Client Sample ID: Kitchen M **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 5/19/2021)

Lead	ND	1.0		µg/L	1	6/1/2021 4:53:10 PM
------	----	-----	--	------	---	---------------------

Lab SampleID: 210513024-151 **Collection Date:** 5/12/2021
Client Sample ID: C1a **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 5/19/2021)

Lead	ND	1.0		µg/L	1	6/1/2021 4:56:56 PM
------	----	-----	--	------	---	---------------------

Lab SampleID: 210513024-152 **Collection Date:** 5/12/2021
Client Sample ID: C1b **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 5/19/2021)

Lead	ND	1.0		µg/L	1	6/1/2021 5:00:38 PM
------	----	-----	--	------	---	---------------------

Lab SampleID: 210513024-153 **Collection Date:** 5/12/2021
Client Sample ID: C1d **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 5/19/2021)

Lead	ND	1.0		µg/L	1	6/1/2021 5:04:20 PM
------	----	-----	--	------	---	---------------------

Adirondack Environmental Services, Inc

Date: 02-Jun-21

CLIENT: Cambridge School District
Project: CCS

LabWork Order: 210513024
PO#:

Lab SampleID: 210513024-154 **Collection Date:** 5/12/2021
Client Sample ID: C2a **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
ICP/MS - EPA 200.8 REV 5.4 Analyst: SM						
(Prep: - 5/19/2021)						
Lead	ND	1.0		µg/L	1	6/1/2021 5:14:55 PM

Lab SampleID: 210513024-155 **Collection Date:** 5/12/2021
Client Sample ID: C2b **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
ICP/MS - EPA 200.8 REV 5.4 Analyst: SM						
(Prep: - 5/19/2021)						
Lead	ND	1.0		µg/L	1	6/1/2021 5:26:05 PM

Lab SampleID: 210513024-156 **Collection Date:** 5/12/2021
Client Sample ID: C2d **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
ICP/MS - EPA 200.8 REV 5.4 Analyst: SM						
(Prep: - 5/19/2021)						
Lead	ND	1.0		µg/L	1	6/1/2021 5:29:48 PM

Lab SampleID: 210513024-157 **Collection Date:** 5/12/2021
Client Sample ID: G1a **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
ICP/MS - EPA 200.8 REV 5.4 Analyst: SM						
(Prep: - 5/19/2021)						
Lead	1.8	1.0		µg/L	1	6/1/2021 5:40:59 PM

Lab SampleID: 210513024-158 **Collection Date:** 5/12/2021
Client Sample ID: G3 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
ICP/MS - EPA 200.8 REV 5.4 Analyst: SM						
(Prep: - 5/19/2021)						
Lead	5.1	1.0		µg/L	1	6/1/2021 5:44:44 PM

Adirondack Environmental Services, Inc

Date: 02-Jun-21

CLIENT: Cambridge School District
Project: CCS

LabWork Order: 210513024
PO#:

Lab SampleID: 210513024-159 **Collection Date:** 5/12/2021
Client Sample ID: G5a **Matrix:** DRINKING WATER
Analyses **Result** **RL Qual Units** **DF** **Date Analyzed**

ICP/MS - EPA 200.8 REV 5.4 **Analyst: SM**
(Prep: - 5/19/2021)

Lead	ND	1.0	µg/L	1	6/1/2021 5:48:28 PM
------	----	-----	------	---	---------------------

Lab SampleID: 210513024-160 **Collection Date:** 5/12/2021
Client Sample ID: G7a **Matrix:** DRINKING WATER
Analyses **Result** **RL Qual Units** **DF** **Date Analyzed**

ICP/MS - EPA 200.8 REV 5.4 **Analyst: SM**
(Prep: - 5/19/2021)

Lead	ND	1.0	µg/L	1	6/1/2021 5:52:13 PM
------	----	-----	------	---	---------------------

Lab SampleID: 210513024-161 **Collection Date:** 5/12/2021
Client Sample ID: G7b **Matrix:** DRINKING WATER
Analyses **Result** **RL Qual Units** **DF** **Date Analyzed**

ICP/MS - EPA 200.8 REV 5.4 **Analyst: SM**
(Prep: - 5/19/2021)

Lead	ND	1.0	µg/L	1	6/1/2021 5:55:59 PM
------	----	-----	------	---	---------------------

Lab SampleID: 210513024-162 **Collection Date:** 5/12/2021
Client Sample ID: G7c **Matrix:** DRINKING WATER
Analyses **Result** **RL Qual Units** **DF** **Date Analyzed**

ICP/MS - EPA 200.8 REV 5.4 **Analyst: SM**
(Prep: - 5/19/2021)

Lead	ND	1.0	µg/L	1	6/1/2021 5:59:41 PM
------	----	-----	------	---	---------------------

Lab SampleID: 210513024-163 **Collection Date:** 5/12/2021
Client Sample ID: G7d **Matrix:** DRINKING WATER
Analyses **Result** **RL Qual Units** **DF** **Date Analyzed**

ICP/MS - EPA 200.8 REV 5.4 **Analyst: SM**
(Prep: - 5/19/2021)

Lead	ND	1.0	µg/L	1	6/1/2021 6:03:23 PM
------	----	-----	------	---	---------------------

Adirondack Environmental Services, Inc

Date: 02-Jun-21

CLIENT: Cambridge School District
Project: CCS

LabWork Order: 210513024
PO#:

Lab SampleID: 210513024-164 **Collection Date:** 5/12/2021
Client Sample ID: G11a **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4						Analyst: SM
(Prep: - 5/19/2021)						
Lead	ND	1.0		µg/L	1	6/1/2021 6:14:32 PM

Lab SampleID: 210513024-165 **Collection Date:** 5/12/2021
Client Sample ID: G11b **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4						Analyst: SM
(Prep: - 5/19/2021)						
Lead	ND	1.0		µg/L	1	6/1/2021 6:33:10 PM

Lab SampleID: 210513024-166 **Collection Date:** 5/12/2021
Client Sample ID: G11c **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4						Analyst: SM
(Prep: - 5/19/2021)						
Lead	ND	1.0		µg/L	1	6/1/2021 6:36:55 PM

Lab SampleID: 210513024-167 **Collection Date:** 5/12/2021
Client Sample ID: G11d **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4						Analyst: SM
(Prep: - 5/19/2021)						
Lead	2.0	1.0		µg/L	1	6/1/2021 6:40:39 PM

Lab SampleID: 210513024-168 **Collection Date:** 5/12/2021
Client Sample ID: G13a **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4						Analyst: SM
(Prep: - 5/19/2021)						
Lead	ND	1.0		µg/L	1	6/1/2021 6:44:24 PM

Adirondack Environmental Services, Inc

Date: 02-Jun-21

CLIENT: Cambridge School District
Project: CCS

LabWork Order: 210513024
PO#:

Lab SampleID: 210513024-169 **Collection Date:** 5/12/2021
Client Sample ID: G15a **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 5/19/2021)

Lead	6.5	1.0		µg/L	1	6/1/2021 6:48:09 PM
------	-----	-----	--	------	---	---------------------

Lab SampleID: 210513024-170 **Collection Date:** 5/12/2021
Client Sample ID: G15b **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 5/19/2021)

Lead	1.6	1.0		µg/L	1	6/1/2021 6:51:52 PM
------	-----	-----	--	------	---	---------------------

Lab SampleID: 210513024-171 **Collection Date:** 5/12/2021
Client Sample ID: G15c **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 5/19/2021)

Lead	1.1	1.0		µg/L	1	6/1/2021 7:03:02 PM
------	-----	-----	--	------	---	---------------------

Lab SampleID: 210513024-172 **Collection Date:** 5/12/2021
Client Sample ID: F17 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 5/19/2021)

Lead	ND	1.0		µg/L	1	6/1/2021 7:06:44 PM
------	----	-----	--	------	---	---------------------

Lab SampleID: 210513024-173 **Collection Date:** 5/12/2021
Client Sample ID: G7e **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 5/19/2021)

Lead	ND	1.0		µg/L	1	6/1/2021 7:10:27 PM
------	----	-----	--	------	---	---------------------

Adirondack Environmental Services, Inc

Date: 02-Jun-21

CLIENT: Cambridge School District
Project: CCS

LabWork Order: 210513024
PO#:

Lab SampleID: 210513024-174 **Collection Date:** 5/12/2021
Client Sample ID: G11e **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
ICP/MS - EPA 200.8 REV 5.4 Analyst: SM (Prep: - 5/19/2021)						
Lead	ND	1.0		µg/L	1	6/1/2021 7:14:10 PM

Lab SampleID: 210513024-175 **Collection Date:** 5/12/2021
Client Sample ID: G21a **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
ICP/MS - EPA 200.8 REV 5.4 Analyst: SM (Prep: - 5/19/2021)						
Lead	ND	1.0		µg/L	1	6/1/2021 7:25:21 PM

Lab SampleID: 210513024-176 **Collection Date:** 5/12/2021
Client Sample ID: B32b **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
ICP/MS - EPA 200.8 REV 5.4 Analyst: SM (Prep: - 5/19/2021)						
Lead	ND	1.0		µg/L	1	6/1/2021 7:29:06 PM

Lab SampleID: 210513024-177 **Collection Date:** 5/12/2021
Client Sample ID: B33a **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
ICP/MS - EPA 200.8 REV 5.4 Analyst: SM (Prep: - 5/19/2021)						
Lead	ND	1.0		µg/L	1	6/1/2021 7:32:50 PM

Lab SampleID: 210513024-178 **Collection Date:** 5/12/2021
Client Sample ID: Football Storage **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
ICP/MS - EPA 200.8 REV 5.4 Analyst: SM (Prep: - 5/19/2021)						
Lead	ND	1.0		µg/L	1	6/1/2021 7:36:35 PM

Adirondack Environmental Services, Inc

Date: 02-Jun-21

CLIENT: Cambridge School District
Project: CCS

LabWork Order: 210513024
PO#:

Lab SampleID: 210513024-179 **Collection Date:** 5/12/2021
Client Sample ID: BiB6 **Matrix:** DRINKING WATER
Analyses **Result** **RL Qual Units** **DF** **Date Analyzed**

ICP/MS - EPA 200.8 REV 5.4 **Analyst: SM**
(Prep: - 5/19/2021)

Lead	ND	1.0	µg/L	1	6/1/2021 7:47:47 PM
------	----	-----	------	---	---------------------

Lab SampleID: 210513024-180 **Collection Date:** 5/12/2021
Client Sample ID: BiB7 **Matrix:** DRINKING WATER
Analyses **Result** **RL Qual Units** **DF** **Date Analyzed**

ICP/MS - EPA 200.8 REV 5.4 **Analyst: SM**
(Prep: - 5/19/2021)

Lead	1.5	1.0	µg/L	1	6/1/2021 7:51:31 PM
------	-----	-----	------	---	---------------------

Lab SampleID: 210513024-181 **Collection Date:** 5/12/2021
Client Sample ID: BiB9 **Matrix:** DRINKING WATER
Analyses **Result** **RL Qual Units** **DF** **Date Analyzed**

ICP/MS - EPA 200.8 REV 5.4 **Analyst: SM**
(Prep: - 5/19/2021)

Lead	3.0	1.0	µg/L	1	6/1/2021 7:55:14 PM
------	-----	-----	------	---	---------------------

Lab SampleID: 210513024-182 **Collection Date:** 5/12/2021
Client Sample ID: BiB10 **Matrix:** DRINKING WATER
Analyses **Result** **RL Qual Units** **DF** **Date Analyzed**

ICP/MS - EPA 200.8 REV 5.4 **Analyst: SM**
(Prep: - 5/19/2021)

Lead	ND	1.0	µg/L	1	6/1/2021 7:58:57 PM
------	----	-----	------	---	---------------------

Lab SampleID: 210513024-183 **Collection Date:** 5/12/2021
Client Sample ID: Admin Womens **Matrix:** DRINKING WATER
Analyses **Result** **RL Qual Units** **DF** **Date Analyzed**

ICP/MS - EPA 200.8 REV 5.4 **Analyst: SM**
(Prep: - 5/19/2021)

Lead	16.1	1.0	X µg/L	1	6/1/2021 8:02:40 PM
------	------	-----	--------	---	---------------------

Adirondack Environmental Services, Inc

Date: 02-Jun-21

CLIENT: Cambridge School District
Project: CCS

LabWork Order: 210513024
PO#:

Lab SampleID: 210513024-184 **Collection Date:** 5/12/2021
Client Sample ID: Admin Mens **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 5/19/2021)

Lead	5.1	1.0		µg/L	1	6/1/2021 8:13:51 PM
------	-----	-----	--	------	---	---------------------

Lab SampleID: 210513024-185 **Collection Date:** 5/12/2021
Client Sample ID: Drivers Ladies **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 5/19/2021)

Lead	1.4	1.0		µg/L	1	6/1/2021 8:32:31 PM
------	-----	-----	--	------	---	---------------------

Lab SampleID: 210513024-186 **Collection Date:** 5/12/2021
Client Sample ID: Driver Mens Room a **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 5/19/2021)

Lead	ND	1.0		µg/L	1	6/1/2021 8:36:15 PM
------	----	-----	--	------	---	---------------------

Lab SampleID: 210513024-187 **Collection Date:** 5/12/2021
Client Sample ID: F16 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 5/19/2021)

Lead	ND	1.0		µg/L	1	6/1/2021 8:40:01 PM
------	----	-----	--	------	---	---------------------

Lab SampleID: 210513024-188 **Collection Date:** 5/12/2021
Client Sample ID: U5 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 5/19/2021)

Lead	ND	1.0		µg/L	1	6/1/2021 8:43:44 PM
------	----	-----	--	------	---	---------------------

Adirondack Environmental Services, Inc

Date: 02-Jun-21

CLIENT: Cambridge School District
Project: CCS

LabWork Order: 210513024
PO#:

Lab SampleID: 210513024-189 **Collection Date:** 5/12/2021
Client Sample ID: B13a **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4						Analyst: SM
(Prep: - 5/19/2021)						
Lead	ND	1.0		µg/L	1	6/1/2021 8:47:28 PM

Lab SampleID: 210513024-190 **Collection Date:** 5/12/2021
Client Sample ID: B13b **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4						Analyst: SM
(Prep: - 5/19/2021)						
Lead	37.9	1.0	X	µg/L	1	6/1/2021 8:51:12 PM

Lab SampleID: 210513024-191 **Collection Date:** 5/12/2021
Client Sample ID: F1 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4						Analyst: SM
(Prep: - 5/19/2021)						
Lead	ND	1.0		µg/L	1	6/1/2021 8:54:55 PM



314 North Pearl Street
Albany, NY 12207
518-434-4546 / FAX: 518-434-0891

EXPERIENCE IS THE SOLUTION

CHAIN OF CUSTODY RECORD

AES Work Order#: **210513024**

COC Reference:
[Blank]

A full service analytical research laboratory offering solutions to environmental concerns

Client Name: Cambridge School District	Address: 245 PARK ST, Cambridge NY, 12816
Send Report to: Rich Austin	Project Name (Location): CCS
Client Phone #: 518-677-8527 x1439	Client PO #:
Client Email: rich.austin@cambridgecsd.org	Samplers Name: Anthony Janock
	Samplers Signature:

AES Sample Number	Client Sample Identification & Location	Date Sampled	Time A=am P=pm	Sample Type			# of Cont's	Preservative	Analysis
				Matrix	C	G			
001	102a	5/12/21	448	WA		X			LEAD
002	102b		4:49						
003	107a		451						
004	107b		451						
005	133		453						
006	F5		502						
007	131		455						
008	B1a		457						
009	B1b		457						
010	F1 B3a		500						
011	B3 B3b		500						
012	B6		521						
013	83		504						
014	B7		523						
015	B8a		524						

Shipment Arrived Via: FedEx UPS Client AES Other: _____

Turnaround Time Requested:
 1 Day 2 Day 3 Day 5 Day Standard
 NOTE: Samples received after 3:30pm are considered next business day.

Special Instructions/Remarks:
[Blank]

Relinquished by: (Signature)	Received by: (Signature)	Date	Time
Relinquished by: (Signature)	Received by: (Signature)	Date	Time
Relinquished by: (Signature) <i>Rich Austin</i>	Received for Laboratory by: 	Date 5/13/21	Time 10:00 am

Sample Temperature Ambient ~ Chilled ~ Chilling Begun Notes: _____	Properly Preserved: Y / N 0=None 1=H ₂ SO ₄ pH<2 2=HNO ₃ pH<2 3=HCl pH<2 4=Na ₂ S ₂ O ₃ 5=NH ₃ Cl 6=Ascorbic Acid 7=FAS 8=ZnAc/NaOH pH>9 9=NaOH pH>10 10=Other _____	Received Within Holding Times: Y / N Notes: _____
Custody Seal Intact: Y / N		
Bottles AES: Y / N		





314 North Pearl Street
Albany, NY 12207
518-434-4546 / FAX: 518-434-0891

CHAIN OF CUSTODY RECORD

AES Work Order#: 210513024

COC Reference:

EXPERIENCE IS THE SOLUTION

A full service analytical research laboratory offering solutions to environmental concerns

Client Name: <u>CAMbridge School District</u>	Address: <u>245 Park Cambridge NY, 12816</u>
Send Report to: <u>Rich Austin</u>	Project Name (Location): <u>CCS</u>
Client Phone #: <u>518-677-8527 x1438</u>	Client PO #:
Client Email: <u>rich.austin@cambridgescd.org</u>	Samplers Name: <u>Anthony Jancek</u>
	Samplers Signature:

AES Sample Number	Client Sample Identification & Location	Date Sampled	Time A=am P=pm	Sample Type			# of Cont's	Preservative	Analysis
				Matrix	C	G			
016	B8b	5/12/21	525	WA		X			LCAD
017	B10a		527						
018	B10b		528						
019	113a		529						
020	113b		529						
021	115		531						
022	117		534						
023	B12a		536						
024	B12b		536						
025	B14a		538						
026	B14b		538						
027	F2		540						
028	B16a		515						
029	B16b		516						
030	B16c		516						

Shipment Arrived Via: FedEx UPS Client AES Other: _____

Special Instructions/Remarks: _____

Turnaround Time Requested:
 1 Day 2 Day 3 Day 5 Day Standard
 NOTE: Samples received after 3:30pm are considered next business day.

Relinquished by: (Signature) 	Received by: (Signature) 	Date <u>5/13/21</u>	Time <u>10:00 am</u>
Relinquished by: (Signature) 	Received by: (Signature) 	Date	Time
Relinquished by: (Signature) 	Received for Laboratory by: 	Date	Time

Sample Temperature Ambient ~ Chilled ~ Chilling Begun Notes: _____	Properly Preserved: Y / N 0=None 1=H ₂ SO ₄ pH<2 2=HNO ₃ pH<2 3=HCl pH<2 4=Na ₂ S ₂ O ₃ 5=NH ₄ Cl 6=Ascorbic Acid 7=FAS 8=ZnAc/NaOH pH>9 9=NaOH pH>10 10=Other _____	Received Within Holding Times: Y / N Notes: _____
Custody Seal Intact: <u>Y / N</u>		
Bottles AES: <u>Y / N</u>		



314 North Pearl Street
Albany, NY 12207
518-434-4546 / FAX: 518-434-0891

EXPERIENCE IS THE SOLUTION

CHAIN OF CUSTODY RECORD

AES Work Order#: 210513024

COC Reference:

A full service analytical research laboratory offering solutions to environmental concerns

Client Name: <u>Cambridge School District</u>	Address: <u>245 Park St, Cambridge NY, 12816</u>	
Send Report to: <u>Rich Austin</u>	Project Name (Location): <u>CCS</u>	Samplers Name: <u>A. Jancsek</u>
Client Phone #: <u>518-677-8527 x1438</u>	Client PO #:	Samplers Signature:
Client Email: <u>rich.austin@cambridgeschool.org</u>		

AES Sample Number	Client Sample Identification & Location	Date Sampled	Time A=am P=pm	Sample Type			# of Cont's	Preservative	Analysis
				Matrix	C	G			
031	B19a	5/12/21	517	Ⓟ	WA				LCAD
032	B19b		517	Ⓟ					
033	B19c		518	Ⓟ					
034	B22		520	Ⓟ					
035	B23		520	Ⓟ					
036	F3		522	Ⓟ					
037	214		523	Ⓟ					
038	F-6		406	Ⓟ					
039	RM 15d		417	Ⓟ					
040	B24		407	Ⓟ					
041	B25		407	Ⓟ					
042	12		410	Ⓟ					
043	15a		413	Ⓟ					
044	15b		415	Ⓟ					
045	15c		417	Ⓟ					

Shipment Arrived Via: FedEx UPS Client AES Other: _____	Special Instructions/Remarks:
--	-------------------------------

Turnaround Time Requested:
 1 Day 2 Day 3 Day 5 Day Standard
 NOTE: Samples received after 3:30pm are considered next business day.

Relinquished by: (Signature)	Received by: (Signature)	Date	Time
Relinquished by: (Signature)	Received by: (Signature)	Date	Time
Relinquished by: (Signature)	Received for Laboratory by:	Date	Time
		<u>5/13/21</u>	<u>10:00 am</u>

Sample Temperature Ambient ~ Chilled ~ Chilling Begun Notes:	Properly Preserved: Y / N 0=None 1=H ₂ SO ₄ pH<2 2=HNO ₃ pH<2 3=HCl pH<2 4=Na ₂ S ₂ O ₃ 5=NH ₄ Cl 6=Ascorbic Acid 7=FAS 8=ZnAc/NaOH pH>9 9=NaOH pH>10 10=Other _____	Received Within Holding Times: Y / N Notes:
Custody Seal Intact: Y / N		
Bottles AES: Y / N		



314 North Pearl Street
Albany, NY 12207
518-434-4546 / FAX: 518-434-0891

EXPERIENCE IS THE SOLUTION

CHAIN OF CUSTODY RECORD

AES Work Order#: 210513024

COC Reference:

A full service analytical research laboratory offering solutions to environmental concerns

Client Name: <u>CAMbridge School District</u>		Address: <u>24 S. Park St. Cambridge NY 12816</u>	
Send Report to: <u>Rich Austin</u>		Project Name (Location):	Samplers Name: <u>A. Janick</u>
Client Phone #: <u>518-677-8527 x1438</u>		Client PO #:	Samplers Signature: <u>[Signature]</u>
Client Email: <u>rich.austin@cambridgescd.org</u>			

AES Sample Number	Client Sample Identification & Location	Date Sampled	Time A=am P=pm	Sample Type			# of Cont's	Preservative	Analysis
				Matrix	C	G			
<u>046</u>	<u>15E</u>	<u>5/12/21</u>	<u>418</u>	<u>WA</u>		<u>X</u>			<u>LEAD</u>
<u>047</u>	<u>15F</u>		<u>418</u>						
<u>048</u>	<u>B 26a</u>		<u>422</u>						
<u>049</u>	<u>B 26b</u>		<u>422</u>						
<u>050</u>	<u>B 26c</u>		<u>423</u>						
<u>051</u>	<u>B 26d</u>		<u>424</u>						
<u>052</u>	<u>B 27a</u>		<u>425</u>						
<u>053</u>	<u>B 27b</u>		<u>425</u>						
<u>054</u>	<u>B 27c</u>		<u>426</u>						
<u>055</u>	<u>B 27d</u>		<u>427</u>						
<u>056</u>	<u>56</u>		<u>431</u>						
<u>057</u>	<u>F-8</u>		<u>430</u>						
<u>058</u>	<u>54</u>		<u>432</u>						
<u>059</u>	<u>52</u>		<u>434</u>						
<u>060</u>	<u>51</u>		<u>434</u>						

Shipment Arrived Via: FedEx <input type="checkbox"/> UPS <input type="checkbox"/> Client <input type="checkbox"/> AES <input type="checkbox"/> Other: _____	Special Instructions/Remarks:
--	-------------------------------

Turnaround Time Requested:
 1 Day 2 Day 3 Day 5 Day Standard
 NOTE: Samples received after 3:30pm are considered next business day.

Relinquished by: (Signature)	Received by: (Signature)	Date	Time
Relinquished by: (Signature)	Received by: (Signature)	Date	Time
Relinquished by: (Signature)	Received for Laboratory by:	Date	Time

Sample Temperature Ambient ~ Chilled ~ Chilling Begun Notes: _____	Properly Preserved: <u>Y / N</u> 0=None 1=H ₂ SO ₄ pH<2 2=HNO ₃ pH<2 3=HCl pH<2 4=Na ₂ S ₂ O ₃ 5=NH ₄ Cl 6=Ascorbic Acid 7=FAS 8=ZnAc/NaOH pH>9 9=NaOH pH>10 10=Other _____	Received Within Holding Times: <u>Y / N</u> Notes: _____
Custody Seal Intact: <u>Y / N</u>		
Bottles AES: <u>Y / N</u>		

4/13



314 North Pearl Street
 Albany, NY 12207
 518-434-4546 / FAX: 518-434-0891

EXPERIENCE IS THE SOLUTION

CHAIN OF CUSTODY RECORD

AES Work Order#: **21C513024**

COC Reference:

A full service analytical research laboratory offering solutions to environmental concerns

Client Name: <i>Cambridge School District</i>	Address: <i>24 S. Park St Cambridge NY, 12816</i>	
Send Report to: <i>Rich Austin</i>	Project Name (Location): <i>CCS</i>	Samplers Name: <i>A. Jancsek</i>
Client Phone #: <i>518-677-8527x1438</i>	Client PO #:	Samplers Signature: <i>[Signature]</i>
Client Email: <i>rich.austin@cambridgescd.org</i>		

AES Sample Number	Client Sample Identification & Location	Date Sampled	Time A=am P=pm	Sample Type			# of Cont's	Preservative	Analysis
				Matrix	C	G			
CW1	50	5/12/21	435	Ⓟ	WA				LEAD
CW2	F9		438	Ⓟ					
CW3	47a		440	Ⓟ					
CW4	47b		440	Ⓟ					
CW5	48a		442	Ⓟ					
CW6	48b		441	Ⓟ					
CW7	46a		444	Ⓟ					
CW8	46b		444	Ⓟ					
CW9	B28		446	Ⓟ					
C70	B29		446	Ⓟ					
C71	44a		448	Ⓟ					
C72	44b		448	Ⓟ					
C73	42a		451	Ⓟ					
C74	40a		453	Ⓟ					
C75	40b		453	Ⓟ					

Shipment Arrived Via: FedEx UPS Client AES Other: _____
 Special Instructions/Remarks:

Turnaround Time Requested:
 1 Day 2 Day 3 Day 5 Day Standard
 NOTE: Samples received after 3:30pm are considered next business day.

Relinquished by: (Signature) <i>[Signature]</i>	Received by: (Signature) <i>[Signature]</i>	Date <i>5/13/21</i>	Time <i>10:00am</i>
Relinquished by: (Signature)	Received by: (Signature)	Date	Time
Relinquished by: (Signature)	Received for Laboratory by:	Date	Time

Sample Temperature <input checked="" type="radio"/> Ambient <input type="radio"/> Chilled ~ Chilling Begun Notes:	Properly Preserved: <input checked="" type="checkbox"/> Y <input type="checkbox"/> N 0=None 5=NH ₄ Cl 1=H ₂ SO ₄ pH<2 6=Ascorbic Acid 2=HNO ₃ pH<2 7=FAS 3=HCl pH<2 8=ZnAc/NaOH pH>9 4=Na ₂ S ₂ O ₃ 9=NaOH pH>10 10=Other _____	Received Within Holding Times: <input checked="" type="checkbox"/> Y <input type="checkbox"/> N Notes:
Custody Seal Intact: <input checked="" type="checkbox"/> Y <input type="checkbox"/> N		
Bottles AES: <input checked="" type="checkbox"/> Y <input type="checkbox"/> N		

5/13



314 North Pearl Street
Albany, NY 12207
518-434-4546 / FAX: 518-434-0891

CHAIN OF CUSTODY RECORD

AES Work Order#: 210513024

COC Reference:

EXPERIENCE IS THE SOLUTION

A full service analytical research laboratory offering solutions to environmental concerns

Client Name: <u>Cambridge School District</u>	Address: <u>245 Park St. Cambridge NY 12816</u>	
Send Report to: <u>Rich Austin</u>	Project Name (Location): <u>CCS</u>	Samplers Name: <u>A. Jancsek</u>
Client Phone #: <u>518-677-8527 x1438</u>	Client PO #:	Samplers Signature:
Client Email: <u>rich.austin@cambridgesd.org</u>		

AES Sample Number	Client Sample Identification & Location	Date Sampled	Time A=am P=pm	Sample Type Matrix C G	# of Cont's	Preservative	Analysis
<u>076</u>	<u>39a</u>	<u>5/12/21</u>	<u>456</u>	<u>WA</u>			<u>LEAD</u>
<u>077</u>	<u>39b</u>		<u>456</u>				
<u>078</u>	<u>38a</u>		<u>500</u>				
<u>079</u>	<u>38b</u>		<u>500</u>				
<u>080</u>	<u>37a</u>		<u>458</u>				
<u>081</u>	<u>37b</u>		<u>458</u>				
<u>082</u>	<u>36a</u>		<u>501</u>				
<u>083</u>	<u>36b</u>		<u>501</u>				
<u>084</u>	<u>35a</u>		<u>504</u>				
<u>085</u>	<u>35b</u>		<u>504</u>				
<u>086</u>	<u>34a</u>		<u>508</u>				
<u>087</u>	<u>34b</u>		<u>508</u>				
<u>088</u>	<u>32a</u>		<u>509</u>				
<u>089</u>	<u>32b</u>		<u>509</u>				
<u>090</u>	<u>32c</u>		<u>510</u>				

Shipment Arrived Via: FedEx UPS Client AES Other: _____

Turnaround Time Requested: Standard

NOTE: Samples received after 3:30pm are considered next business day.

Special Instructions/Remarks:

Received by: (Signature)	Date	Time
Received by: (Signature)	Date	Time
Received for Laboratory by:	<u>5/13/21</u>	<u>10:00 am</u>

Relinquished by: (Signature) _____

Relinquished by: (Signature) _____

Relinquished by: (Signature)

Sample Temperature: Ambient - Chilled ~ Chilling Begun

Notes:

Custody Seal Intact: Y / N

Bottles AES: Y / N

Properly Preserved: Y / N

Received Within Holding Times: Y / N

Notes:

0=None
1=H₂SO₄ pH<2
2=HNO₃ pH<2
3=HCl pH<2
4=Na₂S₂O₃
5=NH₄Cl
6=Ascorbic Acid
7=FAS
8=ZnAc/NaOH pH>9
9=NaOH pH>10
10=Other _____



314 North Pearl Street
 Albany, NY 12207
 518-434-4546 / FAX: 518-434-0891

CHAIN OF CUSTODY RECORD

AES Work Order#: 210513024

COC Reference:

EXPERIENCE IS THE SOLUTION

A full service analytical research laboratory offering solutions to environmental concerns

Client Name: <u>Cambridge School District</u>	Address: <u>245 Park St. Cambridge NY 12816</u>
Send Report to: <u>Rich Austin</u>	Project Name (Location): <u>CCS</u>
Client Phone #: <u>518-677-8527 x1438</u>	Client PO #:
Client Email: <u>rich.austin@cambridgecsd.org</u>	Samplers Name: <u>A. Jancsek</u>
	Samplers Signature:

AES Sample Number	Client Sample Identification & Location	Date Sampled	Time A=am P=pm	Sample Type			# of Cont's	Preservative	Analysis
				Matrix	C	G			
CC1	F10	5/12/21	512	WA		X			LEAD
CC2	31a	↓	513	↓					↓
CC3	31b		513						
CC4	30a		515						
CC5	30b		515						
CC6	29a		516						
CC7	28a		516						
CC8	28b		516						
CC9	27a		519						
100	27b		519						
101	26a		521						
102	26b		521						
103	25a		523						
104	25b		523						
105	24a		525						

Shipment Arrived Via:
 FedEx UPS Client AES Other: _____

Special Instructions/Remarks:

Turnaround Time Requested:
 1 Day 2 Day 3 Day 5 Day Standard
 NOTE: Samples received after 3:30pm are considered next business day.

Relinquished by: (Signature) 	Received by: (Signature) 	Date <u>5/13/21</u>	Time <u>10:22 am</u>
Relinquished by: (Signature)	Received by: (Signature)	Date	Time
Relinquished by: (Signature)	Received for Laboratory by:	Date	Time

Sample Temperature
 Ambient ~ Chilled ~ Chilling Begun
 Notes:
 Custody Seal Intact: Y / N
 Bottles AES: Y / N

Properly Preserved: Y / N
 0=None
 1=H₂SO₄ pH<2
 2=HNO₃ pH<2
 3=HCl pH<2
 4=Na₂S₂O₃
 5=NH₄Cl
 6=Ascorbic Acid
 7=FAS
 8=ZnAc/NaOH pH>9
 9=NaOH pH>10
 10=Other _____

Received Within Holding Times: Y / N
 Notes:



314 North Pearl Street
 Albany, NY 12207
 518-434-4546 / FAX: 518-434-0891

CHAIN OF CUSTODY RECORD

AES Work Order#: **210513024**

COC Reference:

EXPERIENCE IS THE SOLUTION

A full service analytical research laboratory offering solutions to environmental concerns

Client Name: <i>CAMbridge School District</i>	Address: <i>24 S. PARK ST. Cambridge NY, 12816</i>	
Send Report to: <i>Rich Austin</i>	Project Name (Location): <i>CCS</i>	Samplers Name: <i>A. Jancet</i>
Client Phone #: <i>518-677-8527 x1438</i>	Client PO #:	Samplers Signature: <i>[Signature]</i>
Client Email: <i>rich.austin@cambridgeschool.org</i>		

AES Sample Number	Client Sample Identification & Location	Date Sampled	Time A=am P=pm	Sample Type			# of Cont's	Preservative	Analysis
				Matrix	C	G			
100	24b	5/12/21	525	Ⓞ	WA				LEAD
107	23a	✓	527	Ⓞ					
108	23b		527	Ⓞ					
109	58		410	Ⓞ					
110	60		411	Ⓞ					
111	62		412	Ⓞ					
112	64		413	Ⓞ					
113	66a		414	Ⓞ					
114	F13		416	Ⓞ					
115	65a		417	Ⓞ					
116	65b		417	Ⓞ					
117	67a		419	Ⓞ					
118	67b		419	Ⓞ					
119	68a		420	Ⓞ					
120	68b		421	Ⓞ					

Shipment Arrived Via: FedEx UPS Client AES Other: _____

Special Instructions/Remarks: _____

Turnaround Time Requested:
 1 Day 2 Day 3 Day 5 Day Standard

NOTE: Samples received after 3:30pm are considered next business day.

Relinquished by: (Signature) <i>[Signature]</i>	Received by: (Signature) <i>[Signature]</i>	Date <i>5/13/21</i>	Time <i>10:00 am</i>
Relinquished by: (Signature) <i>[Signature]</i>	Received by: (Signature) <i>[Signature]</i>	Date	Time
Relinquished by: (Signature) <i>[Signature]</i>	Received for Laboratory by: <i>[Signature]</i>	Date	Time

Sample Temperature Ambient ~ Chilled ~ Chilling Begun Notes: _____	Properly Preserved: Y / N 0=None 1=H ₂ SO ₄ pH<2 2=HNO ₃ pH<2 3=HCl pH<2 4=Na ₂ S ₂ O ₃ 5=NH ₄ Cl 6=Ascorbic Acid 7=FAS 8=ZnAc/NaOH pH>9 9=NaOH pH>10 10=Other _____	Received Within Holding Times: Y / N Notes: _____
Custody Seal Intact: Y / N		
Bottles AES: Y / N		

8/13



314 North Pearl Street
Albany, NY 12207
518-434-4546 / FAX: 518-434-0891

EXPERIENCE IS THE SOLUTION

CHAIN OF CUSTODY RECORD

AES Work Order#: 210513024

COC Reference:

A full service analytical research laboratory offering solutions to environmental concerns

Client Name: <u>Cambridge School District</u>	Address: <u>24 S. Park St Cambridge NY, 12816</u>
Send Report to: <u>Rich Austin</u>	Project Name (Location): <u>CCS</u>
Client Phone #: <u>518-677-8527 x1438</u>	Client PO #:
Client Email: <u>rich.austin@cambridgesd.org</u>	Samplers Name: <u>A. Janock</u>
	Samplers Signature:

AES Sample Number	Client Sample Identification & Location	Date Sampled	Time A=am P=pm	Sample Type			# of Cont's	Preservative	Analysis
				Matrix	C	G			
121	70a	5/12/21	423	Ⓟ	WA		X		LEAD
122	70b		423	Ⓟ					
123	72		425	Ⓟ					
124	B30a		426	Ⓟ					
125	B30b		428	Ⓟ					
126	B30c		429	Ⓟ					
127	B31a		429	Ⓟ					
128	B31b		430	Ⓟ					
129	B31c		431	Ⓟ					
130	A32 80		435	Ⓟ					
131	82		436	Ⓟ					
132	84a		437	Ⓟ					
133	84b		438	Ⓟ					
134	84c		440	Ⓟ					
135	84d		442	Ⓟ					

Shipment Arrived Via: FedEx UPS Client AES Other: _____	Special Instructions/Remarks:
Turnaround Time Requested: 01 Day 02 Day 3 Day 5 Day <u>Standard</u>	
NOTE: Samples received after 3:30pm are considered next business day.	

Relinquished by: (Signature)	Received by: (Signature)	Date	Time
Relinquished by: (Signature)	Received by: (Signature)	Date	Time
Relinquished by: (Signature) 	Received for Laboratory by: 	5/13/21	10:00 AM

Sample Temperature Ambient ~ Chilled ~ Chilling Begun	Properly Preserved: <u>Y / N</u>	Received Within Holding Times: <u>Y / N</u>
Notes:	0=None 1=H ₂ SO ₄ pH<2 2=HNO ₃ pH<2 3=HCl pH<2 4=Na ₂ S ₂ O ₃	Notes:
Custody Seal Intact: <u>Y / N</u>	5=NH ₄ Cl 6=Ascorbic Acid 7=FAS 8=ZnAc/NaOH pH>9 9=NaOH pH>10 10=Other	
Bottles AES: <u>Y / N</u>		



314 North Pearl Street
Albany, NY 12207
518-434-4546 / FAX: 518-434-0891

EXPERIENCE IS THE SOLUTION

CHAIN OF CUSTODY RECORD

AES Work Order#: 210513024

COC Reference:

A full service analytical research laboratory offering solutions to environmental concerns

Client Name: <i>Cambridge School District</i>	Address: <i>245 Park St. Cambridge NY 12816</i>	
Send Report to: <i>Rich Austin</i>	Project Name (Location): <i>CCS</i>	Samplers Name: <i>A. Jancsek</i>
Client Phone #: <i>518-677-8527x1438</i>	Client PO #:	Samplers Signature: <i>[Signature]</i>
Client Email: <i>rich.austin@cambridgescd.org</i>		

AES Sample Number	Client Sample Identification & Location	Date Sampled	Time A=am P=pm	Sample Type			# of Cont's	Preservative	Analysis
				Matrix	C	G			
136	84e	5/12/21	442	WA		X			LEAD
137	84f		443						
138	Kitchen a		331						
139	Kitchen b		331						
140	Kitchen c		332						
141	Kitchen d		332						
142	Kitchen e		336						
143	Kitchen f		338						
144	Kitchen g		338						
145	Kitchen h		340						
146	Kitchen i		343						
147	Kitchen j		345						
148	Kitchen k		346						
149	Kitchen l		348						
150	Kitchen m		349						

Shipment Arrived Via: FedEx UPS Client AES Other: _____

Turnaround Time Requested:
 1 Day 2 Day 3 Day 5 Day Standard
 NOTE: Samples received after 3:30pm are considered next business day.

Relinquished by: (Signature) <i>[Signature]</i>	Received by: (Signature) <i>[Signature]</i>	Date	Time
Relinquished by: (Signature)	Received by: (Signature)	Date	Time
Relinquished by: (Signature) <i>[Signature]</i>	Received for Laboratory by: <i>[Signature]</i>	Date <i>5/13/21</i>	Time <i>10:00 am</i>

Sample Temperature <input type="checkbox"/> Ambient <input type="checkbox"/> Chilled <input type="checkbox"/> Chilling Begun Notes: _____	Properly Preserved: Y / N 0=None 1=H ₂ SO ₄ pH<2 2=HNO ₃ pH<2 3=HCl pH<2 4=Na ₂ S ₂ O ₃ 5=NH ₂ Cl 6=Ascorbic Acid 7=FAS 8=ZnAc/NaOH pH>9 9=NaOH pH>10 10=Other _____	Received Within Holding Times: Y / N Notes: _____
Custody Seal Intact: Y / N		
Bottles AES: Y / N		

10/13



314 North Pearl Street
Albany, NY 12207
518-434-4546 / FAX: 518-434-0891

EXPERIENCE IS THE SOLUTION

CHAIN OF CUSTODY RECORD

AES Work Order#: 210513024

COC Reference:

A full service analytical research laboratory offering solutions to environmental concerns

Client Name: <u>Cambridge School District</u>	Address: <u>24 S. Park St. Cambridge NY 12916</u>	
Send Report to: <u>Rich Austin</u>	Project Name (Location): <u>CCS</u>	Samplers Name: <u>A. Jancek</u>
Client Phone #: <u>518-677-8527 x1438</u>	Client PO #:	Samplers Signature:
Client Email: <u>rich.austin@cambridgecsd.org</u>		

AES Sample Number	Client Sample Identification & Location	Date Sampled	Time A=am P=pm	Sample Type			# of Cont's	Preservative	Analysis
				Matrix	C	G			
151	C1a	5/12/21	400	WA		X			LEAD
152	C1B		401						
153	C1D		403						
154	C2a		355						
155	C2b		357						
156	C2d		354						
157	G1a		545						
158	G3		546						
159	G5a		548						
160	G7a		550						
161	G7b		551						
162	G7c		553						
163	G7d		553						
164	G11a		556						
165	G11b		557						

Shipment Arrived Via: FedEx <input type="checkbox"/> UPS <input checked="" type="checkbox"/> Client <input type="checkbox"/> AES <input type="checkbox"/> Other: _____	Special Instructions/Remarks:
---	-------------------------------

Turnaround Time Requested:
 1 Day 2 Day 3 Day 5 Day Standard
 NOTE: Samples received after 3:30pm are considered next business day.

Relinquished by: (Signature) 	Received by: (Signature) 	Date <u>5/13/21</u>	Time <u>10:00</u>
Relinquished by: (Signature) 	Received by: (Signature) 	Date	Time
Relinquished by: (Signature) 	Received for Laboratory by: 	Date	Time

Sample Temperature Ambient ~ Chilled ~ Chilling Begun Notes: _____	Properly Preserved: <u>Y / N</u> 0=None 1=H ₂ SO ₄ pH<2 2=HNO ₃ pH<2 3=HCl pH<2 4=Na ₂ S ₂ O ₃ 5=NH ₄ Cl 6=Ascorbic Acid 7=FAS 8=ZnAc/NaOH pH>9 9=NaOH pH>10 10=Other _____	Received Within Holding Times: <u>Y / N</u> Notes: _____
Custody Seal Intact: <u>Y / N</u>		
Bottles AES: <u>Y / N</u>		



314 North Pearl Street
Albany, NY 12207
518-434-4546 / FAX: 518-434-0891

CHAIN OF CUSTODY RECORD

AES Work Order#: 21C513024
COC Reference: _____

EXPERIENCE IS THE SOLUTION

A full service analytical research laboratory offering solutions to environmental concerns

Client Name: Cambridge School District Address: 24 S. Park St. Cambridge, NY 12816
Send Report to: Rich Austin Project Name (Location): CCS Samplers Name: A. Jancek
Client Phone #: 518-677-8527x1438 Client PO #: _____ Samplers Signature: [Signature]
Client Email: rich.austin@cambridgecsd.org

AES Sample Number	Client Sample Identification & Location	Date Sampled	Time A=am P=pm	Sample Type			# of Cont's	Preservative	Analysis
				Matrix	C	G			
166	G71c	5/12/21	558	WA		X			LEAD
167	G11d		558						
168	G13a		600						
169	G15a		602						
170	G15b		602						
171	G15c		602						
172	F17		607						
173	G7e		551						
174	G11e		556						
175	G21a		609						
176	B32b		540						
177	B33a		543						
178	Football storage		610						
179	B1B6		615						
180	B1B7		618						

Shipment Arrived Via: FedEx UPS Client AES Other: _____
Special Instructions/Remarks: _____
Turnaround Time Requested: 1 Day 2 Day 3 Day 5 Day Standard
NOTE: Samples received after 3:30pm are considered next business day.

Relinquished by: (Signature)	Received by: (Signature)	Date	Time
Relinquished by: (Signature)	Received by: (Signature)	Date	Time
Relinquished by: (Signature)	Received for Laboratory by:	Date	Time

Sample Temperature: Ambient ~ Chilled ~ Chilling Begun
Notes: _____
Custody Seal Intact: Y / N
Bottles AES: Y / N

Properly Preserved: Y / N
0=None
1=H₂SO₄ pH<2
2=HNO₃ pH<2
3=HCl pH<2
4=Na₂S₂O₃
5=NH₄Cl
6=Ascorbic Acid
7=FAS
8=ZnAc/NaOH pH>9
9=NaOH pH>10
10=Other _____

Received Within Holding Times: Y / N
Notes: _____

12/13



314 North Pearl Street
Albany, NY 12207
518-434-4546 / FAX: 518-434-0891

CHAIN OF CUSTODY RECORD

AES Work Order#: 210513024

COC Reference:

EXPERIENCE IS THE SOLUTION

A full service analytical research laboratory offering solutions to environmental concerns

Client Name: <u>CAMBRIDGE School District</u>	Address: <u>24 S. PARK ST, CAMBRIDGE NY 12816</u>
Send Report to: <u>Rich Austin</u>	Project Name (Location): <u>CCS</u>
Client Phone #: <u>518-677-8527x1438</u>	Client PO #:
Client Email: <u>rich.austin@cambridgecsd.org</u>	Samplers Name: <u>Anthony Jancek</u>
	Samplers Signature:

AES Sample Number	Client Sample Identification & Location	Date Sampled	Time A=am P=pm	Sample Type			# of Cont's	Preservative	Analysis
				Matrix	C	G			
181	BIB 9	5/12/	620	⊙	WA		X		LEAD
182	BIB 10		620	⊙					
183	ADMIN WOMANS		550	⊙					
184	ADMIN MENS		552	⊙					
185	DRIVER LADIES		553	⊙					
186	DRIVER MENS ROOMA		555	⊙					
187	F16		558	⊙					
188	U5		558	⊙					
189	B13a		538	⊙					
190	B13b	✓	538	⊙	✓		✓		
				A					
				P					
				A					
				P					
				A					
				P					

Shipment Arrived Via: FedEx UPS Client AES Other:

Turnaround (Time Requested):
 1 Day 2 Day 3 Day 5 Day Standard
 NOTE: Samples received after 3:30pm are considered next business day.

Special Instructions/Remarks:

Relinquished by: (Signature) 	Received by: (Signature) 	Date	Time
Relinquished by: (Signature) 	Received by: (Signature) 	Date	Time
Relinquished by: (Signature) 	Received for Laboratory by: 	Date <u>5/13/21</u>	Time <u>10:00am</u>

Sample Temperature <input checked="" type="radio"/> Ambient <input type="radio"/> Chilled <input type="radio"/> Chilling Begun Notes:	Properly Preserved: <input checked="" type="checkbox"/> Y <input type="checkbox"/> N 0=None 1=H ₂ SO ₄ pH<2 2=HNO ₃ pH<2 3=HCl pH<2 4=Na ₂ S ₂ O ₃ 5=NH ₂ Cl 6=Ascorbic Acid 7=FAS 8=ZnAc/NaOH pH>9 9=NaOH pH>10 10=Other	Received Within Holding Times: <input checked="" type="checkbox"/> Y <input type="checkbox"/> N Notes:
Custody Seal Intact: <input checked="" type="checkbox"/> Y <input type="checkbox"/> N		
Bottles AES: <input checked="" type="checkbox"/> Y <input type="checkbox"/> N		

13/13